§ 32.53

in the case of devices not initially transferred by the reporting licensee, the name of the manufacturer or initial transferor.

- (4) If the licensee makes changes to a device possessed by a general licensee, such that the label must be changed to update required information, the report must identify the general licensee, the device, and the changes to information on the device label.
- (5) The report must cover each calendar quarter, must be filed within 30 days of the end of the calendar quarter, and must clearly indicate the period covered by the report.
- (6) The report must clearly identify the specific licensee submitting the report and must include the license number of the specific licensee.
- (7) If no transfers have been made to or from a particular Agreement State during the reporting period, this information shall be reported to the responsible Agreement State agency upon request of the agency.
- (c) The person shall maintain all information concerning transfers and receipts of devices that supports the reports required by this section. Records required by this paragraph must be maintained for a period of 3 years following the date of the recorded event. [65 FR 79189, Dec. 18, 2000]

§ 32.53 Luminous safety devices for use in aircraft: Requirements for license to manufacture, assemble, repair or initially transfer.

An application for a specific license to manufacture, assemble, repair or initially transfer luminous safety devices containing tritium or promethium-147 for use in aircraft, for distribution to persons generally licensed under §31.7 of this chapter, will be approved if:

- (a) The applicant satisfies the general requirements specified in §30.33 of this chapter;
- (b) The applicant submits sufficient information regarding each device pertinent to evaluation of the potential radiation exposure, including:
- (1) Chemical and physical form and maximum quantity of tritium or promethium-147 in each device;
- (2) Details of construction and de-

- (3) Details of the method of binding or containing the tritium or promethium-147:
- (4) Procedures for and results of prototype testing to demonstrate that the tritium or promethium-147 will not be released to the environment under the most severe conditions likely to be encountered in normal use;
- (5) Any quality control procedures proposed as alternatives to those prescribed by §32.55;
- (6) Any additional information, including experimental studies and tests, required by the Commission to facilitate a determination of the safety of the device.
- (c) Each device will contain no more than 10 curies of tritium or 300 millicuries of promethium-147. The levels of radiation from each device containing promethium-147 will not exceed 0.5 millirad per hour at 10 centimeters from any surface when measured through 50 milligrams per square centimeter of absorber.
- (d) The Commission determines that:
- (1) The method of incorporation and binding of the tritium or promethium-147 in the device is such that the tritium or promethium-147 will not be released under the most severe conditions which are likely to be encountered in normal use and handling of the device:
- (2) The tritium or promethium-147 is incorporated or enclosed so as to preclude direct physical contact by any person with it;
- (3) The device is so designed that it cannot easily be disassembled; and
- (4) The device has been subjected to and has satisfactorily passed the prototype tests prescribed by §32.101, Schedule B, of this part.

[30 FR 8192, June 26, 1965, as amended at 33 FR 6463, Apr. 27, 1968; 43 FR 6923, Feb. 17, 1978]

§ 32.54 Same: Labeling of devices.

(a) A person licensed under §32.53 to manufacture, assemble, or initially transfer devices containing tritium or promethium-147 for distribution to persons generally licensed under §31.7 of this chapter shall, except as provided in paragraph (b) of this section, affix to each device a label containing the radiation symbol prescribed by §20.1901 of